

Planning and Zoning,

We request that the below be incorporated into the PD per Coppell Fire Department and Fisher Engineering recommendations.

Final Release Permit Requirements

- Provide Rack Level UL9540A test standards result to Fire Department. (NFPA 855, Section [9.1.5.1](#) and 9.1.5.2.1)
- Provide Hazard Mitigation Analysis to Fire Department for review and approval. (NFPA 855, Section [9.5.2.1](#))
- Provide testing, modeling, and/or a combination of both to demonstrate that a fire involving one BESS unit will not propagate to an adjacent unit. (NFPA 855, Section 9.1.5.1.2)
- Have a registered design professional with expertise in fire engineering approve and interpret the test results and prepare the Hazard Mitigation Analysis. (NFPA 855, Section 9.1.5.2.2)

Thank You,

RavenVolt, Inc.